

15th May 2019 Planning Committee – Additional Representations

Page	Site Address	Application No.	Comment
85	49A Surrenden Road, Brighton	BH2018/03921	<p>Transport team advise that the access road would need to be a minimum of 2.75m wide for a fire engine to gain access and it needs to get within 45m of the building in question. At its narrowest point the access road is 2.8m wide.</p> <p>The agent has confirmed that the building is used ancillary to the main dwelling at present. Family and guests for the main house stay in it when required.</p>

NB. Representations received after midday the Friday before the date of the Committee meeting will not be reported (Sub-Committee resolution of 23 February 2005).

→

